

**MANUFACTURER'S DECLARATION
OF CONFORMITY****We:****Leuze electronic GmbH + Co. KG**

In der Braike 1

73277 Owen

Germany

Vendor ID 388 (0x0184)

declare under our own responsibility that the product(s):

IO-Link Device

MS 300 product family

Device ID 5201

to which this declaration refers conform to:

- ☒ IO-Link Interface and System Specification, V1.1.4, June 2024
(NOTE 1)
- ☒ IO Device Description, V1.1.4, June 2024
- ☐ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)
- ☒ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

TR-002469, PB2024-118

Issued at Owen, 13.03.2025**Authorized signatory****Name:** Ingo Baumgardt**Title:** Director of PC3**Signature:****Name:** Gerhard Hofgärtner**Title:** Head of CC4**Signature:**

Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is V1.1.4, June 2024

MD-Version: V1.1.4 / 2024-09

Part A - Additional conformance to Device Profiles

	Specification
<input checked="" type="checkbox"/>	IO-Link Common Profile Specification, V1.2, Jan. 2024
<input type="checkbox"/>	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.2, Sept. 2024
<input type="checkbox"/>	IO-Link Profile Smart Sensors 2 nd Edition Specification, V1.2, Jan. 2024

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
Power-on wake-up readiness delay according to Exception 24-01	This Device may delay the communication up to 10 s after power-on. This may result in failure reactions of the system following power-on.

Annex – Conform products

50150597 MS 342
