



America

CERTIFICATE

No. U8V 14 04 22795 105

Holder of Certificate: Leuze electronic GmbH + Co. KG

Liebigstrasse 4
82256 Fürstenfeldbruck
GERMANY

Production Facility(ies): 70507

Certification Mark:



Product: Safety Relays
(Safety Relay)

Model(s): MSI-RM2B-01, MSI-RM2B-02

Parameters:

Supply Voltage:	24 VDC ± 20%
Rated Contact Load:	3A / 230 V
Current Consumption:	32 mA
Protection Class:	II
Temperature Ambient:	50°C

See attachment for Conditions of Acceptability.

Tested according to: CAN/CSA-C22.2 No.14:2013
UL 508/R:2013-10

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: PI1401083-000

Date, 2014-04-24

Page 1 of 2



ATTACHMENT TO CERTIFICATE NO. U8V 14 04 22795 105 for Leuze electronic GmbH + Co. KG



America

Safety Relay

CONDITIONS OF ACCEPTABILITY:

When installed in the end use equipment, the following are among the considerations to be made:

- 1) When installed in the end use equipment, the following are among the considerations to be made:
- 2) Improper or inappropriate use can result in danger to the life and limbs of the machine operator or in damage to property.
- 3) The relevant regulations are valid for the use of MSI-RM2B Safety relays. The category of Safety Relay function must be determined under consideration of the risk evaluation of the machinery. The responsible local authorities are available to answer questions related to safety issues.
- 4) The mechanical and electrical installation is to be performed by trained specialists.
- 5) The voltage supply to the system must be switched off before and during installation.
- 6) Contact mechanisms with positive-guided contacts must be implemented for the contact multiplication of the release circuits.
- 7) If the "Automatic Start" operating mode is switched, this mode remains active even after an operating voltage failure. If connecting single-channel AOPDs or Safety Switches in acc. to Cat. 2, EN ISO 13849-1: 2008, the testing stipulated in this standard is to be ensured separately.
- 8) The MSI-RM2B safety relays are not suitable for open wall mounting and must be built into protective enclosure minimum of IP54/NEMA 3. Proper enclosure type shall be added and evaluated per environmental conditions of the end user.
- 9) Finger-safe in accordance with DIN VDE 0106 Section 100, maximum stripped length of the connecting cables: 8 mm
- 10) In order to prevent the output contacts from welding together, an external fuse of max. 5 A quick-action or 3.15A delay-action must be interposed.
- 11) Terminal B1 and B3 are not intended for operating external devices, rather only for supplying potential-free contacts.
- 12) Switching off the supply voltage for operating purposes is to be made impossible.
- 13) Integration of the Safety Relay in the control circuits according to EN ISO 13849-1:2008.
- 14) Lay the supply voltage cables separately according to EN ISO 13849-1:2008
Connecting the Signal Lines:
- 15) For reliable and touch-safe contacts, isolate the connection ends as follows:
Screw terminals: 7 mm
Spring-cage terminals: 8 mm