



Product Service

C E R T I F I C A T E

No. Z10 15 04 68636 003

Holder of Certificate: Leuze electronic GmbH + Co.KGIn der Braike 1
73277 Owen/Teck
GERMANY**Factory(ies):**

68636

Certification Mark:**Product:****Electro-Sensitive Protective Equipment
Type 3****Model(s):****Laser Scanner
RS4-4, RS4-4E, RS4-2E, RS4-4M, RS4-2M,
RS4-6, RS4-6E, RS4-6M****Parameters:**

Operating temperature:	0°C – 50°C
Power supply:	24 VDC +20% / -30%
IP class:	IP65
Humidity:	95%
Response time:	min. 80ms adjustable

**Tested
according to:**2006/42/EC
EN ISO 13849-1:2008 (Cat.3 PL d)
EN 61508-1:2010 (SIL 2)
EN 61508-2:2010 (SIL 2)
EN 61508-3:2010 (SIL 2)
EN 61508-4:2010 (SIL 2)
EN 62061:2005/A1:2013 (SILCL 2)
EN 61496-1:2013
IEC 61496-3(ed.2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 717501618**Valid until:** 2020-04-27**Date,** 2015-04-28
(Günter Greil)

Page 1 of 1

